

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-1597:105 Page 1 of 1

CATEGORY: Photoelectric Smoke Detectors

LISTEE: TEPG – US, 91 Technology Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 Fax (978) 731-8881

DESIGN: Models 430559, 430560 and 430562 photoelectric type smoke detectors. Model 430560 employs an integral 135°F heat sensor. This heat sensor is intended for use as a supplemental device to the smoke detector. Refer to listee's data sheet for additional detailed system description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, air velocity rating and UL label.

APPROVAL: Listed as photoelectric type smoke detectors for use with separately listed compatible fire alarm control units. Intended for use with separately listed Models 430569, 430570 or 430567 (CSFM Listing No. 7300-1597:107) detector bases. For indoor use only.

XLF: 7272-0026:219

04-09-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 9, 2003**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager